



TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 8/5/19-8/11/19

Sewer Division

Weekly Report

Total flow to the Plant from P.S. #2: 123,477

Average Daily Flow: 17,639

Total Gallons of Septic accepted for the week: 30,500

Total Precipitation for the week (inches): 0.17

Operational issues and other duties for the week: Make Rounds

Recorded Septage Data. Rottotiller Rhs #4, 5.

switched air pump and exercise valve station #1, 2.

Rottotiller Rhs P.U. Gen worked on Gen P.S. #2.

changed oil pump #1, 2. Station #1

Dredwater sampling for D.E.S.