



TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 10/21/19 - 10/27/19

Sewer Division Weekly Report

Total flow to the Plant from P.S. #2: 120,723

Average Daily Flow: 17,246

Total Gallons of Septic accepted for the week: 18,800

Total Precipitation for the week (inches): 1.64

Operational issues and other duties for the week: Made Panels

Switched air pump and exercised valve station #1,2

Recorded Septage Data, Replaced Ribs

attended wastewater Training class in Franklin

Replaced Black Heater, Removed Radiator From Gen P.S. #1 For Repair