TOWN OF WAKEFIELD, NEW HAMPSHIRE
PUBLIC WORKS DEPARTMENT
SEWER DIVISION
RTE 16 WHITE MOUNTAIN HIGHWAY
SANBORNVILLE NH 03872
TELEPHONE: (603) 522-3590
DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 11/4/19 - 11/10/19

Sewer Division
Weekly Report

Total flow to the Plant from P.S. #2: 114,326

Average Daily Flow: 16,332

Total Gallons of Septic accepted for the week: 43,300

Total Precipitation for the week (inches): 0.47

Operational issues and other duties for the week: Made Rounds

Recorded Septage Data, Rotated Ribs, Rotorilled Ribs #2, 4, 5

Did water Sampling For State, Turned on Heat P.S. #1, 2, plant

Replaced Radiator Gen P.S. #1, winterized Rib Valve Heads at plant

Switched air pump and exercised valve station #12

Lubracated Plant Gate. Turned in Monthly Report