



TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE: (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 11/11/19 - 11/17/19

Sewer Division

Weekly Report

Total flow to the Plant from P.S. #2: 108,372

Average Daily Flow: 15,481

Total Gallons of Septic accepted for the week: 11,750

Total Precipitation for the week (inches): 0.21

Operational issues and other duties for the week: Mark Raul

switched air pump and tested valve station #1,2

Revised Rb1, Recycled Septage Data

pumped out wet wells station #1,2, Reprimed pumps

Installed New Block Heater at wet pump station #2