



TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 12/2/19 - 12/8/19

Sewer Division

Weekly Report

Total flow to the Plant from P.S. #2: 114,414

Average Daily Flow: 16,344

Total Gallons of Septic accepted for the week: 10,250

Total Precipitation for the week (inches): 1.12

Operational issues and other duties for the week: Maule Ranch

switched air pump and exercise valve station #1, 2

Recorded seepage data, worked monthly report

Rebated Ribs. Removed snow from pump station and plant