




TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 12/9/19 - 12/15/19

Sewer Division

Weekly Report

Total flow to the Plant from P.S. #2: 149,161

Average Daily Flow: 21,308

Total Gallons of Septic accepted for the week: 2250

Total Precipitation for the week (inches): 3.43

Operational issues and other duties for the week: Mark Rand

Switched air pump on tertiary side Station #1.2

Recorded Septage Data. Recorded Septage Data. Rotated Ribs

Put Rototiller and Mower away for Season. Turned in Monthly Report

Heavy Dept Digtest Hole To Locate plant Tank Pipes