



TOWN OF WAKEFIELD, NEW HAMPSHIRE

PUBLIC WORKS DEPARTMENT

SEWER DIVISION

RTE 16 WHITE MOUNTAIN HIGHWAY

SANBORNVILLE NH 03872

TELEPHONE: (603) 522-3590

DPWDIRECTOR@WAKEFIELDNH.COM

Date for the week of: 7/8/19-7/14/19

Sewer Division

Weekly Report

Total flow to the Plant from P.S. #2: 110.399

Average Daily Flow: 15.771

Total Gallons of Septic accepted for the week: 26.250

Total Precipitation for the week (inches): 1.43

Operational issues and other duties for the week: Macke Round

Switched air pump on Exercise Valve Station #1.2

Recorded Septage Data. Rotated Pabs

Rotated Pabs #3 & 6. Replaced Leaking Drainage Pump #2 Station #2

Repaired Drive Belt Pump #2 Station #1